



Strojirenský zkušební ústav, s. p. (Engineering Test Institute, Public Enterprise)
Hudcova 56b, 621 00 Brno, Czech Republic

CERTIFICATE

Number: **B-39-00003-12**

Manufacturer: MICOS spol. s r.o.
Vápenice 17, 796 01 Prostějov, Czech Republic
ID No.: 00533394

Product: Plastic switchboard

Type designation: MRK 10/20

The Engineering Test Institute certifies hereby that the characteristics of the sample of the product concerned have been found to be in conformity with applicable requirements for the


temperature change test (-40°C/+70°C) according to ČSN EN 60068-2-14 ed.2:2010,
ingress protection: IK10 according to ČSN EN 50102:1997 and
ingress protection: IP54 according to ČSN EN 60529:1993.

The present Certificate has been issued on the basis of Test Report No. 39-9433 of 2012-01-11, issued by Engineering Test Institute.

The rules for using the Certificate are specified on Page 2.

Brno 2012-01-11




Jiří Rozsival
Deputy Director