



Strojirenský zkušební ústav, s.p.
(Engineering Test Institute, Public Enterprise)
Product Certification Body
Hudcova 424/56b, 621 00 Brno, Czech Republic

CERTIFICATE

B-32-00503-17

Manufacturer: MICOS spol. s r.o.
Vápenice 17, 796 01 Prostějov
Czech Republic

Company ID No.: 00533394

Product: Wall-mounted distribution box

Type designation: MTeH UNI

The Engineering Test Institute, Public Enterprise, hereby certifies that the characteristics of the sample of the product concerned have been found conforming to the applicable requirements

- for the IP20 degree of protection provided by enclosures as per ČSN EN 60529:1993,
- for the IP40 degree of protection provided by enclosures as per ČSN EN 60529:1993 if the conditions specified in the installation manual are met,
- for the IK07 degree of protection provided by enclosures against external mechanical impacts as per ČSN EN 62262:2004.

The present Certificate has been issued on the basis of Final Report 32-0351 of 2017-05-16, issued by the Engineering Test Institute, Public Enterprise.

Certification scheme applied: ČSN EN ISO/IEC 17067:2014, Scheme 1a.

The rules for using the Certificate are specified on Page 2.

Brno, 2017-05-16




Ing. Aleš Onderek
Deputy Director

B-32-00503-17, page 1 (2)

Strojirenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika
Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic

www.szutest.cz



RULES FOR USING THE CERTIFICATE:

For the purposes of placing the product on the market the Certificate may only be used provided the normative documents specified on Page 1 remain valid.

This Certificate may only be used as a certificate for the product specified on Page 1. This also applies to its use in advertising, promotional and commercial materials. Unauthorised or deceptive use of the Certificate may result in its withdrawal.

It is prohibited to change, amend or overwrite the data contained in the Certificate.

The Certificate may not be used for the product changed without the consent of the Engineering Test Institute, Public Enterprise, in such a way that conformity with the technical requirements specified on Page 1 has been affected.

